


ALUMINUM COATED STEEL RECTANGULAR MESH OR GALVANIZED WOVEN RECTANGULAR MESH FENCE WITH NOT LESS THAN 9 HORIZONTAL BARS.

TOP AND BOTTOM BARS TO BE NOT LESS THAN NO.9 GAUGE. INTERMEDIATE BARS NOT LESS THAN NO.11 GAUGE. VERTICAL STAY BARS NOT GREATER THAN 6" APART AND NOT LESS THAN NO.11 GAUGE.

ALL END POSTS SHALL HAVE ONE BRACE; ALL CORNER AND INTERMEDIATE BRACE OR PULL POSTS SHALL HAVE TWO BRACES, WITH A MAXIMUM SPACING BETWEEN BRACES OF 600 FEET.

LINE POSTS TO HAVE ANCHOR PLATES. CONCRETE TO BE INCLUDED IN BID PRICE FOR WOVEN WIRE FENCE.



ALUMINUM COATED STEEL RECTANGULAR MESH OR

NOT LESS THAN 9 HORIZONTAL BARS.


TOP AND BOTTOM BARS TO BE NOT LESS THAN NO.9 GAUGE INTERMEDIATE BARS NOT LESS THAN NO.11 GAUGE. VERTICAL STAY BARS NOT GREATER THAN 6" APART AND NOT LESS THAN NO.11 GAUGE


ALL POSTS AND TIMBER BRACES SHALL BE GIVEN A PRESERVATIVE TREATMENT AS PER SUB-SECTION 726.01 EXCEPTING WESTERN RED CEDAR.

ALL END POSTS SHALL HAVE ONE BRACE, ALL CORNER AND INTERMEDIATE BRACE OR PULL POSTS SHALL HAVE TWO BRACES, WITH A MAXIMUM SPACING BETWEEN BRACES OF 600 FEET.

WHEN EXPOSED ROCK IS ENCOUNTERED THE FENCE SHALL BE ATTACHED TO STEEL POSTS SET AS DESCRIBED UNDER SUBSECTION 620.04.

POSTS TO HAVE A MINIMUM OF  $4\frac{1}{2}$ " DIAMETER.






- A 25'-0" OR TO 1.0' ± 0.5" FROM NEAREST FENCE POST (AT RIGHT ANGLE TO POWER LINE )
- B MAXIMUM DISTANCE I.O ( ± 0.5")
  C MINIMUM DISTANCE I.O ( ± 1.0")
- D 2.0" ( + 0.5") E MINIMUM DISTANCE 6.0
- I CONNECTOR, SUITABLE FOR WIRE GAUGES UTILIZED AND
- 2 CONNECTOR, FOR DISSIMILAR METALS
  3 GROUND ROD CLAMP
- 4 COPPER CLAD STEEL CORE GROUND ROD 5/8" x 8'-0"


5 CONDUCTOR NO.6 AWG COPPER SOFT DRAWN OR NO.4 AWG ALUMINUM


INSTALLATION METHOD OF PROTECTIVE

GROUNDING AT POWER LINE CROSSING




ELEVATION (BRIDGE WITH PARAPET WALLS)







VARIABLE




ELEVATION (AT CULVERT)







(FOR POST ARRANGEMENT OVER STREAMS SEE SKETCH BELOW)

CROSSING AT STREAMS





WOVEN WIRE FENCE DETAILS



STANDARD